



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
1090 Bristol Rd
Mountainside, NJ 07092

Report Number: 17-06-02285

Received Date: 06/16/2017

Reported Date: 06/19/2017

Sampled By: Lee Wasserman

Tech Certification #:

Project/Test Address: 170108; Seth Boyden Elementary; 274 Boyden Avenue; Maplewood, NJ 07040

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narr
17-06-02285-001	1-14-SB-DW	06/15/2017	1ST RM 105 HALL	<1.00	06/18/2017	
17-06-02285-002	2-14-SB-DW	06/15/2017	2ND RM 105 HALL	<1.00	06/18/2017	
17-06-02285-003	3-BLANK-ASTM	06/15/2017	SUN ROOM	<1.00	06/18/2017	

Method: SM 3113B-2010

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion