

Building	Date Collected	Analysis Date	Sample ID	Sample Description	Concentration (ppb)
ALL SAMPLES ALL SCHOOLS ARE 1ST DRAW SAMPLES					
S Orange Middle	5-7-2-17	5-15-2017	1-SOM-WC	JANITOR CLOSET 1	<1.00
S Orange Middle	5-7-2-17	5-15-2017	3-SOM-WC	RM 107 HALL	<1.00
S Orange Middle	5-7-2-17	5-15-2017	6-SOM-WC	STOARGE HALL 14	1.81
S Orange Middle	5-7-2-17	5-15-2017	7-SOM-WC	STORAGE HALL 14	1.26
S Orange Middle	5-7-2-17	5-15-2017	8-SOM-WC	JANITOR CLOSET 26	<1.00
S Orange Middle	5-7-2-17	5-15-2017	9-SOM-S	MAIN OFFICE	<1.00
S Orange Middle	5-7-2-17	5-15-2017	10-SOM-WC	MAIN OFFICE	2.78
S Orange Middle	5-7-2-17	5-15-2017	12-SOM-NS	NURSE OFFICE	6.49
S Orange Middle	5-7-2-17	5-15-2017	13-SOM-WC	JANITOR CLOSET 22 HALL	<1.00
S Orange Middle	5-7-2-17	5-15-2017	14-SOM-TL	TEACHER LOUNGE	2.64
S Orange Middle	5-7-2-17	5-15-2017	15-SOM-WC	RM 283 HALL	<1.00
S Orange Middle	5-7-2-17	5-15-2017	18-SOM-WC	389 HALL	<1.00
S Orange Middle	5-7-2-17	5-15-2017	19-SOM-WC	359 HALL	<1.00
S Orange Middle	5-7-2-17	5-15-2017	20-SOM-FP	KITCHEN	4.25
S Orange Middle	5-7-2-17	5-15-2017	21-SOM-IM	KITCHEN	<1.00
S Orange Middle	5-7-2-17	5-15-2017	22-ASTM BLANK	BLANK	<1.00
South Mountain Annex	5-6-2017	5-15-20`17	1-SMA-DW	RM 114	5.64
South Mountain Annex	5-6-2017	5-15-20`17	2-SMA-DW	RM 117	2.82
South Mountain Annex	5-6-2017	5-15-20`17	3-SMA-DW	RM 115	1.92
South Mountain Annex	5-6-2017	5-15-20`17	4-SMA-DW	RM 116	3.02
South Mountain Annex	5-6-2017	5-15-20`17	5-SMA-DW	BOILER HALL	2.54
South Mountain Annex	5-6-2017	5-15-20`17	6-SMA-TL	TEACHER LOUNGE	3.54
South Mountain Annex	5-6-2017	5-15-20`17	7-SMA-NS	NURSE OFFICE	3.06
South Mountain Annex	5-6-2017	5-15-20`17	8-SMA-WC	RM 103 HALL	28.5
South Mountain Annex	5-6-2017	5-15-20`17	10-SMA-DW	RM 102	2.16
South Mountain Annex	5-6-2017	5-15-20`17	11-SMA-DW	RM 103	30.3
South Mountain Annex	5-6-2017	5-15-20`17	12-ASTM-BLANK	BLANK	<1.00
Jefferson Elementary	5-6-2017	5-12-2017	1-JE-DW	RM B110 HALL	<1.00
Jefferson Elementary	5-6-2017	5-12-2017	3-JE-DW	RM A113	6.15

Jefferson Elementary	5-6-2017	5-12-2017	4-JE-DW	RM A114		5.69
Jefferson Elementary	5-6-2017	5-12-2017	5-JE-DW	RM A116		3.78
Jefferson Elementary	5-6-2017	5-12-2017	6-JE-DW	RM A115 LEFT		7.10
Jefferson Elementary	5-6-2017	5-12-2017	7-JE-DW	RM A115 RIGHT		3.20
Jefferson Elementary	5-6-2017	5-12-2017	8-JE-DW	RM A118		1.85
Jefferson Elementary	5-6-2017	5-12-2017	9-JE-DW	RM A119		2.58
Jefferson Elementary	5-6-2017	5-12-2017	10-JE-NS	NURSE OFFICE		<1.00
Jefferson Elementary	5-6-2017	5-12-2017	11-JE-NS	NURSE BATH		1.19
Jefferson Elementary	5-6-2017	5-12-2017	12-JE-DW	RM B111 HALL		<1.00
Jefferson Elementary	5-6-2017	5-12-2017	13-JE-DW	RM B111 HALL		<1.00
Jefferson Elementary	5-6-2017	5-12-2017	14-JE-WC	RM A203 HALL		<1.00
Jefferson Elementary	5-6-2017	5-12-2017	16-JE-WC	RM B201 HALL		<1.00
Jefferson Elementary	5-6-2017	5-12-2017	19-JE-WC	RM A304 HALL		<1.00
Jefferson Elementary	5-6-2017	5-12-2017	20-JE-TL	TEACHER LOUNGE		3.33
Jefferson Elementary	5-6-2017	5-12-2017	21-ASTM BLANK	BLANK		<1.00
Montrose School	5-7-2017	5-11-2017	1-MS-DW	RM B3 HALL		5.06
Montrose School	5-7-2017	5-11-2017	2-MS-DW	RM B5 HALL		5.69
Montrose School	5-7-2017	5-11-2017	3-MS-S	RM 107 SINK		3.83
Montrose School	5-7-2017	5-11-2017	4-MS-S	RM 105		<1.00
Montrose School	5-7-2017	5-11-2017	5-MS-DW	RM 105		<1.00
Montrose School	5-7-2017	5-11-2017	6-MS-DW	RM 105 HALL		2.04
Montrose School	5-7-2017	5-11-2017	7-MS-DW	RM 101		<1.00
Montrose School	5-7-2017	5-11-2017	8-ASTM	BLANK		<1.00
Clinton Elementary	5-6-2017	5-15-2017	1-CE-WC	RM 101 HALL		<1.00
Clinton Elementary	5-6-2017	5-15-2017	2-CE-WC	RM 101 HALL		<1.00
Clinton Elementary	5-6-2017	5-15-2017	3-CE-S	CAFETERIA		<1.00
Clinton Elementary	5-6-2017	5-15-2017	4-CE-DW	RM HALL 109		1.75
Clinton Elementary	5-6-2017	5-15-2017	5-CE-DW	RM HALL 109		<1.00
Clinton Elementary	5-6-2017	5-15-2017	6-CE-DW	RM 106 HALL		1.32
Clinton Elementary	5-6-2017	5-15-2017	7-CE-DW	RM 102 HALL		4.89
Clinton Elementary	5-6-2017	5-15-2017	8-CE-DW	RM 105 HALL		1.03
Clinton Elementary	5-6-2017	5-15-2017	9-CE-DW	RM 105 HALL		<1.00
Clinton Elementary	5-6-2017	5-15-2017	10-CE-NS	NURSE OFFICE		3.68
Clinton Elementary	5-6-2017	5-15-2017	11-CE-NS	NURSE BATHROOM		<1.00
Clinton Elementary	5-6-2017	5-15-2017	12-CE-TL	TEACHER LOUNGE		<1.00
Clinton Elementary	5-6-2017	5-15-2017	13-CE-S	RM 223		1.07
Clinton Elementary	5-6-2017	5-15-2017	17-CE-DW	RM 211 HALL		6.65
Clinton Elementary	5-6-2017	5-15-2017	18-CE-DW	RM 214 HALL		3.49
Clinton Elementary	5-6-2017	5-15-2017	19-CE-DW	RM 214 HALL		<1.00
Clinton Elementary	5-6-2017	5-15-2017	20-ASTM- BLANK	ASTM BLANK		<1.00
Marshall Elementary	5-6-2017	5-12-2017	1-ME-S	RM 120		6.88
Marshall Elementary	5-6-2017	5-12-2017	3-ME-DW	RM 121		2.55
Marshall Elementary	5-6-2017	5-12-2017	4-ME-S	RM 119		2.44
Marshall Elementary	5-6-2017	5-12-2017	5-ME-S	RM 122		3.90

Marshall Elementary	5-6-2017	5-12-2017	6-ME-DW	RM 122 HALL	2.10
Marshall Elementary	5-6-2017	5-12-2017	7-ME-DW	RM 124 HALL	2.50
Marshall Elementary	5-6-2017	5-12-2017	8-ME-DW	RM 125	<1.00
Marshall Elementary	5-6-2017	5-12-2017	9-ME-DW	RM 126	<1.00
Marshall Elementary	5-6-2017	5-12-2017	10-ME-DW	RM 127	<1.00
Marshall Elementary	5-6-2017	5-12-2017	11-ME-DW	RM 128	<1.00
Marshall Elementary	5-6-2017	5-12-2017	12-ME-WC	CAFETERIA WATERCOOLER	<1.00
Marshall Elementary	5-6-2017	5-12-2017	13-ME-DW	RM 108 HALL	2.54
Marshall Elementary	5-6-2017	5-12-2017	14-ME-DW	RM 108 HALL	2.86
Marshall Elementary	5-6-2017	5-12-2017	15-ME-TL	TEACHER LOUNGE	<1.00
Marshall Elementary	5-6-2017	5-12-2017	16-ME-NS	NURSE SINK	<1.00
Marshall Elementary	5-6-2017	5-12-2017	17-ME-S	RM 101	2.12
Marshall Elementary	5-6-2017	5-12-2017	18-ME-S	RM 101	1.16
Marshall Elementary	5-6-2017	5-12-2017	19-ME-DW	RM 143	<1.00
Marshall Elementary	5-6-2017	5-12-2017	20-ME-DW	RM 203 HALL	1.43
Marshall Elementary	5-6-2017	5-12-2017	21-ME-DW	RM 213	1.07
Marshall Elementary	5-6-2017	5-12-2017	22-ME-DW	RM 209	<1.00
Marshall Elementary	5-6-2017	5-12-2017	23-ME-DW	RM 210	<1.00
Marshall Elementary	5-6-2017	5-12-2017	24-ME-DW	RM 211	<1.00
Marshall Elementary	5-6-2017	5-12-2017	25-ASTM BLANK	BLANK	<1.00
Underhill Field	5-6-2017	5-12-2017	2-NFH-IM	NEW FIELD HOUSE	<1.00
Underhill Field	5-6-2017	5-12-2017	4-NFH-DW	BOYS SHOWER	1.18
Underhill Field	5-6-2017	5-12-2017	5-NFH-DW	NEW F H EXTERIOR	<1.00
Underhill Field	5-6-2017	5-12-2017	6-NFH-DW	NEW F H EXTERIOR	<1.00
Underhill Field	5-6-2017	5-12-2017	7-CS-S	CONCESSION STAND	15.3
Underhill Field	5-6-2017	5-12-2017	8-UF-BLANK	BLANK	<1.00
Seth Boyden Elem	5-6-2017	5-11-2017	1-SB-DW	RM G6 HALL	1.93
Seth Boyden Elem	5-6-2017	5-11-2017	2-SB-DW	RM G2	2.79
Seth Boyden Elem	5-6-2017	5-11-2017	3-SB-DW	RM G1	3.89
Seth Boyden Elem	5-6-2017	5-11-2017	4-SB-DW	G12 HALL	1.74
Seth Boyden Elem	5-6-2017	5-11-2017	5-SB-DW	G12 HALL	<1.00
Seth Boyden Elem	5-6-2017	5-11-2017	6-SB-DW	G14 HALL	<1.00
Seth Boyden Elem	5-6-2017	5-11-2017	7-SB-DW	G14 HALL	1.97
Seth Boyden Elem	5-6-2017	5-11-2017	8-SB-DW	CAFETERIA	<1.00
Seth Boyden Elem	5-6-2017	5-11-2017	9-SB-DW	CAFETERIA	<1.00
Seth Boyden Elem	5-6-2017	5-11-2017	10-SB-DW	RM 102 HALL	1.30
Seth Boyden Elem	5-6-2017	5-11-2017	11-SB-DW	OFFICE FOYER	7.56
Seth Boyden Elem	5-6-2017	5-11-2017	12-SB-DW	OFFICE FOYER	6.74
Seth Boyden Elem	5-6-2017	5-11-2017	13-BS-NS	NURSE OFFICE	1.44
Seth Boyden Elem	5-6-2017	5-11-2017	14-SB-DW	RM 105 HALL	444
Seth Boyden Elem	5-6-2017	5-11-2017	15-SB-DW	RM 105 HALL	<1.00
Seth Boyden Elem	5-6-2017	5-11-2017	16-SB-DW	RM 203 HALL	1.11
Seth Boyden Elem	5-6-2017	5-11-2017	19-SB-DW	RM 206 HALL	<1.00
Seth Boyden Elem	5-6-2017	5-11-2017	21-SB-BLANK	BLANK	<1.00

Columbia H.S.	5-7-2017	5-15-2017	1-HS-NS	NURSE OFFICE	5.46
Columbia H.S.	5-7-2017	5-15-2017	3-HS-NS	NURSE BATH STAFF	3.73
Columbia H.S.	5-7-2017	5-15-2017	6-HS-WC	C134 HALL	<1.00
Columbia H.S.	5-7-2017	5-15-2017	7-HS-DW	B114 HALL	3.20
Columbia H.S.	5-7-2017	5-15-2017	8-HS-DW	B114 HALL	1.48
Columbia H.S.	5-7-2017	5-15-2017	9-HS-DW	D105 HALL	1.39
Columbia H.S.	5-7-2017	5-15-2017	10-HS-DW	D105 HALL	1.03
Columbia H.S.	5-7-2017	5-15-2017	11-HS-DW	A129 HALL	<1.00
Columbia H.S.	5-7-2017	5-15-2017	12-HS-FP	KITCHEN	6.35
Columbia H.S.	5-7-2017	5-15-2017	13-HS-FP	KITCHEN	1.48
Columbia H.S.	5-7-2017	5-15-2017	14-HS-IM	KITCHEN	<1.00
Columbia H.S.	5-7-2017	5-15-2017	16-HS-DW	BLACK BOX HALL	6.05
Columbia H.S.	5-7-2017	5-15-2017	17-HS-DW	BLACK BOX HALL	2.21
Columbia H.S.	5-7-2017	5-15-2017	18-HS-DW	A241 HALL	1.38
Columbia H.S.	5-7-2017	5-15-2017	19-HS-DW	A241 HALL	2.19
Columbia H.S.	5-7-2017	5-15-2017	20-HS-DW	D203 HALL	1.20
Columbia H.S.	5-7-2017	5-15-2017	21-HS-DW	D203 HALL	<1.00
Columbia H.S.	5-7-2017	5-15-2017	22-HS-TL	TEACHER LOUNGE WC	<1.00
Columbia H.S.	5-7-2017	5-15-2017	23-HS-TL	TEACHER LOUNGE SINK	3.13
Columbia H.S.	5-7-2017	5-15-2017	25-HS-DW	B230 HALL	3.56
Columbia H.S.	5-7-2017	5-15-2017	26-HS-DW	B230 HALL	8.10
Columbia H.S.	5-7-2017	5-15-2017	30-HS-DW	C229 HALL	<1.00
Columbia H.S.	5-7-2017	5-15-2017	31-HS-DW	BOYS BATH HALL 3RD FL	2.46
Columbia H.S.	5-7-2017	5-15-2017	32-HS-DW	D301 HALL	1.02
Columbia H.S.	5-7-2017	5-15-2017	36-HS-DW	B328 HALL	2.05
Columbia H.S.	5-7-2017	5-15-2017	37-HS-DW	B328 HALL	8.39
Columbia H.S.	5-7-2017	5-15-2017	38-HS-HE	2ND FLR	3.39
Columbia H.S.	5-7-2017	5-15-2017	39-ASTM BLANK	BLANK	<1.00
Administration Bld	5-7-2017	5-15-2017	1-AB-FC	KITCHEN SINK	3.40
Administration Bld	5-7-2017	5-15-2017	2-AB-BLANK	BLANK	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	1-TE-WC	RM G16 HALL	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	2-TE-WC	RM G24 HALL	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	4-TE-WC	RM G24C HALL	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	5-TE-WC	RM G24C HALL	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	6-TE-WC	RM 108 HALL	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	9-TE-WC	RM 117 HALL	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	10-TE-WC	RM 117 HALL	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	11-TE-NS	NURSE OFFICE	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	12-TE-WC	RM 125 HALL	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	13-TE-WC	RM 125 HALL	2.60
Tuscan Elementary	5-6-2017	5-12-2017	14-TE-WC	RM 120	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	15-TE-DW	RM 122	46.1
Tuscan Elementary	5-6-2017	5-12-2017	16-TE-DW	RM 123	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	17-TE-WC	RM 202 HALL	<1.00
Tuscan Elementary	5-6-2017	5-12-2017	18-TE-S	TAILER 3 SINK	5.15

Tuscan Elementary	5-6-2017	5-12-2017	19-TE-BLANK	BLANK		<1.00
South Mountain Elem	5-6-2017	5-15-2017	1-SME-S	RM 3		17.2
South Mountain Elem	5-6-2017	5-15-2017	2-SME-DW	RM 5 HALL		1.30
South Mountain Elem	5-6-2017	5-15-2017	3-SME-WC	RM 9		<1.00
South Mountain Elem	5-6-2017	5-15-2017	4-SME-WC	RM 120 HALL		<1.00
South Mountain Elem	5-6-2017	5-15-2017	5-SME-WC	RM 120 HALL		<1.00
South Mountain Elem	5-6-2017	5-15-2017	6-SME-DW	RM 107 HALL		1.37
South Mountain Elem	5-6-2017	5-15-2017	7-SME-DW	RM 107 HALL		<1.00
South Mountain Elem	5-6-2017	5-15-2017	8-SME-DW	RM 107		2.21
South Mountain Elem	5-6-2017	5-15-2017	9-SME-NS	NURSE BATH		2.46
South Mountain Elem	5-6-2017	5-15-2017	10-SME-S			5.61
South Mountain Elem	5-6-2017	5-15-2017	11-SME-DW	RM 205 HALL		<1.00
South Mountain Elem	5-6-2017	5-15-2017	12-SME-S	RM 2009		1.68
South Mountain Elem	5-6-2017	5-15-2017	13-SME-BLANK	BLANK		<1.00
Maplewood Middle	5-7-2017	5-12-2017	1-MM-WC	HALL BY 502		<1.00
Maplewood Middle	5-7-2017	5-12-2017	2-MM-TL	TEACHER LOUNGE		46.8
Maplewood Middle	5-7-2017	5-12-2017	3-MM-WC	HALL BY 503		<1.00
Maplewood Middle	5-7-2017	5-12-2017	5-MM-WC	RM 138 HALL		<1.00
Maplewood Middle	5-7-2017	5-12-2017	6-MM-NS	NURSE OFFICE		1.11
Maplewood Middle	5-7-2017	5-12-2017	7-MM-NS	NURSE BATH		1.72
Maplewood Middle	5-7-2017	5-12-2017	8-MM-WC	RM 153 HALL		<1.00
Maplewood Middle	5-7-2017	5-12-2017	9-MM-WC	GIRLS LOCKER RM HALL		<1.00
Maplewood Middle	5-7-2017	5-12-2017	10-MM-DW	GIRLS LOCKER RM		18.0
Maplewood Middle	5-7-2017	5-12-2017	12-MM	BOYS LOCKER RM HALL		6.76
Maplewood Middle	5-7-2017	5-12-2017	15-MM-FP	KTICHEN		1.43
Maplewood Middle	5-7-2017	5-12-2017	16-MM-FP	KTICHEN		16.7
Maplewood Middle	5-7-2017	5-12-2017	17-MM-IM	KTICHEN		<1.00
Maplewood Middle	5-7-2017	5-12-2017	18-MM-WC	RM 290 HALL		<1.00
Maplewood Middle	5-7-2017	5-12-2017	19-MM-WC	RM 286 HALL		<1.00
Maplewood Middle	5-7-2017	5-12-2017	20-MM-DW	RM 162 HALL		2.85
Maplewood Middle	5-7-2017	5-12-2017	21-ASTM BLANK	BLANK		<1.00